



ADDENDUM TO BIDDING DOCUMENTS

Date: October 14, 2016

From: City of Farmington, 110 West Columbia Farmington, MO 63640

To: All Prospective Bidders

Project: **Engler Park Dressing Room Building**

Subject: **Addendum No. 1**

Notice: This addendum modifies the original Bidding Documents and becomes part of the Contract Documents. Make the following modifications and place this Addendum in the Bid Documents.

This Addendum consists of the following:

Make the necessary additions or deletions to the above project bid documents.

1. Please add 1- 10" floor drain and all materials needed to plumb the drain to the sanitary sewer lines in the bathroom section. The bathroom floor grade must also be modified to allow for proper drainage in the bathroom.
2. There are 3 on demand type RHEEM RTE-9, 240v, 30gpm water heaters (or approved equal) specified in the project. Please remove 1 from the total. We will be utilizing 1 unit for the 2 sinks shown on the drawing that are located in the bathroom and adjoining dressing room.

All costs for the work associated with this addendum shall be considered as included in the bid items as noted in the specifications and lump sum bid amount for the work and no additional compensation will be allowed.

All other terms, conditions, requirements, and qualifications of the bid document remain unchanged by this Addendum.

The bid date, time, and location for receipt of Bids are unchanged by this Addendum.

This addendum must be signed and included with the bid forms.

Bidder's Company Name
(please print)

Bidder's Name
(please print)

Bidder's Signature

End Of Document